



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán / Accredited Testing Laboratory, Authorised Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body.

Central Laboratory - Testing Department Brno

Hněvkovského 77, 617 00 Brno, Czech Republic
tel.: +420 734 432 093, e-mail: zadelak@tzus.cz, www.tzus.eu

TEST REPORT

issued by Testing Laboratory

No. 060-057500

**on watertightness of ACO Access Cover Solid ASSIST
according to ČSN EN 1253-4:2016**

Ordering Party: ACO Industries k.s.
Address: 582 22 Příbyslav, Havlíčkova 260, Czech Republic
Company ID: 48119458
Manufacturer: ACO Industries k.s.
Address: 582 22 Příbyslav, Havlíčkova 260, Czech Republic
Test sample: ACO Access Cover Solid ASSIST GS 600x600 B125
Order No.: Z060110233

Number of pages of the Test Report incl. title page: 3 Pages of annexes: 1

Prepared by:


Ing. Pavel Juránek, Ph.D.
test technician - specialist

Approved by:


Ing. Martin Zadělak
head of the Testing Department

Print No.: 1
Number of prints: 2



Brno, 12. 3. 2024

Declaration: 1) The test results in this Report relate only to the tested article and they do not substitute any other documents
2) The Test Report must be copied as a whole only otherwise a written consent of the testing laboratory is needed.

1. Sample data

Evidence number: the test was carried out in the manufacturer's laboratory
 Sample: ACO Access Cover Solid ASSIST 600x600 B125
 Article number: 415212
 Load class: B125
 Order / contract: Z060110233
 Date of test conducting: 25.1.2024

From the ACO Access Cover Solid (GS/SS) ASSIST (opening aid with integrated gas spring) and/or ACO Access Cover Solid ASSIST GS/FR (fire resistant) portfolio was for test performance defined sample ACO Access Cover Solid ASSIST 600x600 B125.

The test specimens were not tailored before testing. Testing was carried out on the whole product set which consists of cover and its frame. Furthermore, the frame was imbedded into the concrete class C 35/45 to manufacturer's technical specification.

Technical design of tested subject is given in the Annex 5.1 of this test report.

2. Test methods

ČSN EN 1253-4	Gullies for buildings – Part 4: Access covers, Cl. 7.3.1 Watertightness
Deviations from a standard procedure or the use of non-standardized methods: were not applied.	

Watertightness

The access cover shall be flooded with a (10±1) mm head of water for a period of (15±1) min. The test shall be deemed to have been passed if, during this period, no water has penetrated to the underside.

3. Test results

The test was carried out on: 25.1.2024
 The test was performed by: Ing. Pavel Juránek, Ph.D.

Data on the person who performed the test, test conditions and equipment used are listed in the test minutes. Apparatuses and measuring instruments that used have been certified pursuant to a valid plan of the testing laboratory Brno.

3.1 Watertightness according to the ČSN EN 1253-4, Cl. 7.3.1

ACO Access Cover Solid ASSIST 600x600 B125		
test no.	test period	test observation
1	15 min.	no water penetration to the underside of cover



3.2 Photo documentation




Figure 1: Watertightness test set up - ACO Access Cover Solid ASSIST 600x600 B125




Figure 2: Watertightness test – no water penetration

4. Test evaluation

The cover, when tested to ČSN EN 1253-4, Cl. 7.3.1 prevented the ingress of surface water to the underside – ACO Access Cover meets requirement.

Watertightness: Class Wt - test has been passed

The test result is valid for products manufactured in ACO Industries k.s.

5. Annexes

5.1 Technical design no. 415212 - ACO Access Cover Solid ASSIST 600x600 B125

END OF THE TEST REPORT

